# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1001 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 120 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1002 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 110 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1003 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 114 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1004 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 198 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 42

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1005 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 120 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1006 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 116 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1007 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 113 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1008 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 116 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1009 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 112 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 42

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1010 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
93313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 116 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1011 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 112 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 260047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1012 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 118 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1013 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 112 [n/min]
pulse rate

bei 55 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1014 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 112 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1015 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 120 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1016 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 116 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1017 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 116 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1018 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 112 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1019 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 116 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1020 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 30 [l/h]*
lower measuring range limit

Impulszahl 112 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 42 i

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1021 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 118 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2I-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1022 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 118 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12.06.2024

Prüfer P421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1023 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 120 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12.06.2024

Prüfer P421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1024 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 118 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1025 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 110 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1026 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 118 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1027 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 118 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1028 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
93313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 114 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1029 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 118 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1030 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 110 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1031 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 118 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1032 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 112 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1033 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 120 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1034 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 120 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer [illegible]

417101586

# Prüfprotokoll OGM$^{plus}$

| | |
|---|---|
| Model number: | 280047 |
| Model description: | Oval gear meter PLUS 01200 |
| OGM PLUS 01200PPEPPKKE-G1/2i-99-0005m-P | |
| Materials of construction: | PP, EDPM, PEEK, ceramic |
| Signal output (standard): | 5,0 ml/pulse, 200 pulses/l |
| Max. pump size: | 120 / 144 l/h (50/60Hz) |
| Semiconductor junction: | PNP |
| Serial number: | 736732 / 22424 / 1035 |

ECOLAB

Year of manufacture: 2024

Made in Germany by:
Ecolab Engineering GmbH
Raiffeisenstrasse 7
83313 Siegsdorf

Anlaufgrenze 20 [l/h]*
lower measuring range limit

Impulszahl 116 [n/min]
pulse rate

bei 35 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 12. Juni 2024

Prüfer P 421

417101586