HERSTELLERERKLÄRUNG

zur trinkwasserhygienischen Eignung nach der deutschen Trinkwasserverordnung und den UBA-Bewertungsgrundlagen

Hersteller: Ecolab Engineering GmbH

Produkt/Produktfamilie: U-DG1-III Metering unit EPDM, Metering unit DG3.1/III EPDM

Artikelnummern: 10240055, 1168

Erklärung

Die Ecolab Engineering GmbH erklärt in alleiniger Verantwortung als Hersteller, dass die oben bezeichneten Produkte in der angegebenen Ausführung und bei bestimmungsgemäßer Verwendung die derzeit in Deutschland anwendbaren trinkwasserhygienischen Anforderungen erfüllen.

Die von Ecolab gelieferten Geräte sind nicht als Trinkwasserquelle oder zur Aufbereitung von Trinkwasser bestimmt. Ihr Zweck besteht darin, aus einem chemischen Konzentrat und zugeführtem Wasser eine verdünnte Gebrauchslösung bereitzustellen.

Die Geräte sind mit einer Sicherungseinrichtung gegen Rückfließen ausgestattet. Aufgrund des Anschlusses an die Wasserversorgung können jedoch Geräteteile bis zur Sicherungseinrichtung bestimmungsgemäß oder potenziell mit Trinkwasser in Berührung kommen. Für diese Bereiche werden die anwendbaren trinkwasserhygienischen Anforderungen berücksichtigt.

Die trinkwasserberührten Werkstoffe und Materialien erfüllen, soweit jeweils anwendbar:

- die allgemeinen Anforderungen der §§ 14 und 15 Trinkwasserverordnung (TrinkwV);
- die zum Ausstellungsdatum rechtsverbindlichen Anforderungen der UBA-Bewertungsgrundlagen für metallene Werkstoffe, Kunststoffe und andere organische Materialien sowie Emails und keramische Werkstoffe; und
- sonstige anwendbare nationale UBA-Regelungsdokumente und technische Anforderungen für den erklärten Anwendungsbereich.

Nachweisgrundlage und Lieferantendokumentation

Ecolab führt eine produktbezogene Dokumentation der potenziell trinkwasserberührten Komponenten. Die Bewertung beruht auf den von den jeweiligen Lieferanten bereitgestellten Informationen und Nachweisen, insbesondere Hersteller- und Lieferantenerklärungen, gültigen Zertifikaten oder Konformitätsbestätigungen, Prüfberichten, Werkstoff- und Materialangaben sowie, soweit anwendbar, Werkszeugnissen 2.2 oder Abnahmeprüfzeugnissen 3.1 nach DIN EN 10204. Die Unterlagen werden den Komponenten und Produktvarianten zugeordnet und im Rahmen der internen Dokumentations-, Rückverfolgbarkeits- und Änderungsprozesse aufbewahrt.

Nationale Konformitätsbestätigung und Gültigkeit

Diese Herstellererklärung ist die nationale Konformitätsbestätigung des Herstellers für die bezeichnete Produktausführung auf Grundlage der TrinkwV, der anwendbaren UBA-Bewertungsgrundlagen und der vorstehend beschriebenen Nachweise. Sie dient auch während der Übergangszeit nach der Delegierten Verordnung (EU) 2024/370 in Deutschland als Konformitätsnachweis, sofern sie am 31. Dezember 2026 ordnungsgemäß vorliegt und gültig ist und die weiteren Übergangsvoraussetzungen erfüllt sind. Sie gilt bei bestimmungsgemäßer Verwendung und fortbestehender Nachweisgrundlage; relevante Änderungen an Produktaufbau, trinkwasserberührten Komponenten, Werkstoffen oder Lieferquellen erfordern eine Neubewertung. Die Übergangsnutzung endet spätestens am 31. Dezember 2032.

Ort, Datum	Siegsdorf, 30.10.2026	
Name / Funktion	M. Niederbichler / Geschäftsführer	D. Rodriguez / Regulatory Affairs Manager
Unterschrift		

MANUFACTURER DECLARATION

on hygienic suitability for drinking-water contact under the German Drinking Water Ordinance and UBA evaluation criteria

Manufacturer: Ecolab Engineering GmbH

Product / Product Family: U-DG1-III Metering unit EPDM, Metering unit DG3.1/III EPDM

Article numbers: 10240055, 1168

Declaration

Ecolab Engineering GmbH declares under its sole responsibility as manufacturer that the products identified above, in the specified configuration and when used as intended, meet the drinking-water hygiene requirements currently applicable in Germany.

The equipment supplied by Ecolab is not intended to serve as a source of drinking water or to treat drinking water. Its purpose is to provide a diluted use solution prepared from a concentrated chemical product and supplied water.

The equipment is fitted with a backflow prevention device. However, because the equipment is connected to the water supply, equipment parts located up to the backflow prevention device may, as intended or potentially, come into contact with drinking water. The applicable drinking-water hygiene requirements are considered for these areas.

Where applicable, the wetted materials comply with:

- the general requirements of Sections 14 and 15 of the German Drinking Water Ordinance (TrinkwV);
- the UBA evaluation criteria for metallic materials, plastics and other organic materials, and enamels and ceramic materials that are legally binding on the date of issue; and
- other applicable national UBA regulatory documents and technical requirements for the declared field of application.

Evidence base and supplier documentation

Ecolab maintains product-specific documentation for components that may come into contact with drinking water. The assessment is based on information and evidence provided by the respective suppliers, in particular manufacturer and supplier declarations, valid certificates or conformity confirmations, test reports, material information and, where applicable, inspection documents 2.2 or 3.1 in accordance with DIN EN 10204. The documents are assigned to the relevant components and product variants and are retained under Ecolab's internal documentation, traceability and change-control processes.

National conformity confirmation and validity

This manufacturer declaration is the manufacturer's national conformity confirmation for the identified product configuration, based on the TrinkwV, the applicable UBA evaluation criteria and the evidence described above. It also serves as evidence of conformity in Germany during the transition under Commission Delegated Regulation (EU) 2024/370, provided it has been duly established and is valid on 31 December 2026 and the other transitional conditions are met. It applies when the product is used as intended and the supporting evidence remains adequate; relevant changes to the product design, wetted components, materials or sources of supply require reassessment. Transitional use ends no later than 31 December 2032.

Place, date	Siegsdorf, 30.10.2026	
Name / function	M. Niederbichler / Company Manager	D. Rodriguez / Regulatory Affairs Manager
Signature		